



LABORATORY ANALYTICAL REPORT

Client: Oglala Lakota College
 Project: PWS 084690028 Piya Wiconi
 Lab ID: R06030106-001
 Client Sample ID: Janitor Closet

Report Date: 03/27/06
 Collection Date: 03/08/06 12:07
 Date Received: 03/08/06
 Matrix: DRINKING WATER

Analyses	Result	Units	Qual	MCL/		Method	Analysis Date / By
				RL	QCL		
INORGANIC PARAMETERS							
Nitrogen, Nitrate as N	0.89	mg/L		0.10		1 E300.0	03/09/06 12:48/JMH
DRINKING WATER VOLATILE ORGANIC COMPOUNDS							
Benzene	ND	ug/L		0.50	5	1 E524.2	03/15/06 15:35/SN
Bromobenzene	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
Bromochloromethane	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
Bromodichloromethane	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
Bromoform	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
Bromomethane	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
n-Butylbenzene	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
sec-Butylbenzene	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
tert-Butylbenzene	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
Carbon tetrachloride	ND	ug/L		0.50	5	1 E524.2	03/15/06 15:35/SN
1,2-Dichloroethane	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
Chlorobenzene	ND	ug/L		0.50	100	1 E524.2	03/15/06 15:35/SN
Chlorodibromomethane	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
Chloroethane	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
Chloroform	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
Chloromethane	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
2-Chlorotoluene	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
4-Chlorotoluene	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
1,2-Dibromo-3-chloropropane	ND	ug/L		1.0		1 E524.2	03/15/06 15:35/SN
Dibromomethane	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
1,2-Dichlorobenzene	ND	ug/L		0.50	600	1 E524.2	03/15/06 15:35/SN
1,3-Dichlorobenzene	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
1,4-Dichlorobenzene	ND	ug/L		0.50	75	1 E524.2	03/15/06 15:35/SN
Dichlorodifluoromethane	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
1,1-Dichloroethane	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
1,2-Dibromoethane	ND	ug/L		0.50	5	1 E524.2	03/15/06 15:35/SN
1,1-Dichloroethene	ND	ug/L		0.50	7	1 E524.2	03/15/06 15:35/SN
cis-1,2-Dichloroethene	ND	ug/L		0.50	70	1 E524.2	03/15/06 15:35/SN
trans-1,2-Dichloroethene	ND	ug/L		0.50	100	1 E524.2	03/15/06 15:35/SN
1,2-Dichloropropane	ND	ug/L		0.50	5	1 E524.2	03/15/06 15:35/SN
1,3-Dichloropropane	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
2,2-Dichloropropane	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
1,1-Dichloropropene	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
cis-1,3-Dichloropropene	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN
trans-1,3-Dichloropropene	ND	ug/L		0.50		1 E524.2	03/15/06 15:35/SN

Report RL - Analyte reporting limit.
 Definitions: QCL - Quality control limit.

MCL - Maximum contaminant level.
 ND - Not detected at the reporting limit.



LABORATORY ANALYTICAL REPORT

Client: Oglala Lakota College
Project: PWS 084690028 Piya Wiconi
Lab ID: R06030106-001
Client Sample ID: Janitor Closet

Report Date: 03/27/06
Collection Date: 03/08/06 12:07
Date Received: 03/08/06
Matrix: DRINKING WATER

Analyses	Result	Units	Qual	RL	MCL/		Method	Analysis Date / By
					QCL	DF		
DRINKING WATER VOLATILE ORGANIC COMPOUNDS								
Ethylbenzene	ND	ug/L		0.50	700	1	E524.2	03/15/06 15:35/SN
Hexachlorobutadiene	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
Isopropylbenzene	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
p-Isopropyltoluene	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
Methylene chloride	ND	ug/L		0.50	5	1	E524.2	03/15/06 15:35/SN
Naphthalene	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
n-Propylbenzene	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
Styrene	ND	ug/L		0.50	100	1	E524.2	03/15/06 15:35/SN
1,1,1,2-Tetrachloroethane	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
1,1,2,2-Tetrachloroethane	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
Tetrachloroethene	ND	ug/L		0.50	5	1	E524.2	03/15/06 15:35/SN
Toluene	ND	ug/L		0.50	1000	1	E524.2	03/15/06 15:35/SN
1,2,3-Trichlorobenzene	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
1,2,4-Trichlorobenzene	ND	ug/L		0.50	70	1	E524.2	03/15/06 15:35/SN
1,1,1-Trichloroethane	ND	ug/L		0.50	200	1	E524.2	03/15/06 15:35/SN
1,1,2-Trichloroethane	ND	ug/L		0.50	5	1	E524.2	03/15/06 15:35/SN
Trichloroethene	ND	ug/L		0.50	5	1	E524.2	03/15/06 15:35/SN
Trichlorofluoromethane	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
1,2,3-Trichloropropane	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
Trihalomethanes, Total	ND	ug/L		0.50	80	1	E524.2	03/15/06 15:35/SN
1,2,4-Trimethylbenzene	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
1,3,5-Trimethylbenzene	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
Vinyl chloride	ND	ug/L		0.50	2	1	E524.2	03/15/06 15:35/SN
m+p-Xylenes	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
o-Xylene	ND	ug/L		0.50		1	E524.2	03/15/06 15:35/SN
Xylenes, Total	ND	ug/L		0.50	10000	1	E524.2	03/15/06 15:35/SN
Surr: p-Bromofluorobenzene	101	%REC			75-130		E524.2	03/15/06 15:35/SN
Surr: 1,2-Dichloroethane-d4	97.6	%REC			75-130		E524.2	03/15/06 15:35/SN
Surr: Toluene-d8	96.8	%REC			75-130		E524.2	03/15/06 15:35/SN
DRINKING WATER HERBICIDE PARAMETERS								
2,4-D	ND	ug/L		1	70	1	E515.1	03/18/06 00:36/eli-b
2,4-DB	ND	ug/L		2		1	E515.1	03/18/06 00:36/eli-b
Dalapon	ND	ug/L		2	200	1	E515.1	03/18/06 00:36/eli-b
Dicamba	ND	ug/L		0.2		1	E515.1	03/18/06 00:36/eli-b
Dichlorprop	ND	ug/L		1		1	E515.1	03/18/06 00:36/eli-b
Dinoseb	ND	ug/L		1	7	1	E515.1	03/18/06 00:36/eli-b
Pentachlorophenol	ND	ug/L		0.04	1	1	E515.1	03/18/06 00:36/eli-b

Report RL - Analyte reporting limit.
Definitions: QCL - Quality control limit.

MCL - Maximum contaminant level.
ND - Not detected at the reporting limit.



LABORATORY ANALYTICAL REPORT

Client: Oglala Lakota College
Project: PWS 084690028 Piya Wiconi
Lab ID: R06030106-001
Client Sample ID: Janitor Closet

Report Date: 03/27/06
Collection Date: 03/08/06 12:07
Date Received: 03/08/06
Matrix: DRINKING WATER

Analyses	Result	Units	Qual	RL	MCL/		Method	Analysis Date / By
					QCL	DF		
DRINKING WATER HERBICIDE PARAMETERS								
Picloram	ND	ug/L		0.5	500	1	E515.1	03/18/06 00:36/eli-b
2,4,5-TP (Silvex)	ND	ug/L		0.2	50	1	E515.1	03/18/06 00:36/eli-b
Surr: DCAA	77.7	%REC			70-130		E515.1	03/18/06 00:36/eli-b
DRINKING WATER ENDOTHALL ANALYSIS								
Endothall	ND	ug/L		8.0	100	1	E548.1	03/20/06 13:54/eli-b
Surr: 2,4-Dichlorophenylacetic acid	104	%REC			70-130		E548.1	03/20/06 13:54/eli-b
DRINKING WATER GLYPHOSATE ANALYSIS								
Glyphosate	ND	ug/L		5	700	5	E547	03/23/06 14:29/eli-c
DRINKING WATER DIQUAT ANALYSIS								
Diquat	ND	ug/L		0.4	20	1	E549.2	03/13/06 16:14/eli-c
DRINKING WATER ORGANOHALIDE PESTICIDE PARAMETERS								
Alachlor	ND	ug/L		0.1	2	1	E505	03/14/06 02:43/eli-c
Aldrin	ND	ug/L		0.01		1	E505	03/14/06 02:43/eli-c
Aroclor 1016	ND	ug/L		0.08		1	E505	03/14/06 02:43/eli-c
Aroclor 1221	ND	ug/L		2		1	E505	03/14/06 02:43/eli-c
Aroclor 1232	ND	ug/L		0.5		1	E505	03/14/06 02:43/eli-c
Aroclor 1242	ND	ug/L		0.3		1	E505	03/14/06 02:43/eli-c
Aroclor 1248	ND	ug/L		0.1		1	E505	03/14/06 02:43/eli-c
Aroclor 1254	ND	ug/L		0.1		1	E505	03/14/06 02:43/eli-c
Aroclor 1260	ND	ug/L		0.2		1	E505	03/14/06 02:43/eli-c
gamma-BHC (Lindane)	ND	ug/L		0.01	0.2	1	E505	03/14/06 02:43/eli-c
Chlordane	ND	ug/L		0.2	2	1	E505	03/14/06 02:43/eli-c
Dieldrin	ND	ug/L		0.01		1	E505	03/14/06 02:43/eli-c
Endrin	ND	ug/L		0.01	2	1	E505	03/14/06 02:43/eli-c
Heptachlor	ND	ug/L		0.01	0.4	1	E505	03/14/06 02:43/eli-c
Heptachlor epoxide	ND	ug/L		0.01	0.2	1	E505	03/14/06 02:43/eli-c
Hexachlorobenzene	ND	ug/L		0.01	1	1	E505	03/14/06 02:43/eli-c
Hexachlorocyclopentadiene	ND	ug/L		0.02	50	1	E505	03/14/06 02:43/eli-c
Methoxychlor	ND	ug/L		0.05	40	1	E505	03/14/06 02:43/eli-c
Toxaphene	ND	ug/L		1	3	1	E505	03/14/06 02:43/eli-c
Surr: Tetrachloro-m-xylene	84.0	%REC			65-125		E505	03/14/06 02:43/eli-c
Surr: Decachlorobiphenyl	202	%REC	S		60-140		E505	03/14/06 02:43/eli-c

- Surrogates are an added ELI Quality Assurance measure. Decachlorobiphenyl is outside of acceptance range.

DRINKING WATER EDB AND DBCP PARAMETERS

Report RL - Analyte reporting limit.
Definitions: QCL - Quality control limit.
 S - Spike recovery outside of advisory limits.

MCL - Maximum contaminant level.
 ND - Not detected at the reporting limit.



LABORATORY ANALYTICAL REPORT

Client: Oglala Lakota College
Project: PWS 084690028 Piya Wiconi
Lab ID: R06030106-001
Client Sample ID: Janitor Closet

Report Date: 03/27/06
Collection Date: 03/08/06 12:07
Date Received: 03/08/06
Matrix: DRINKING WATER

Analyses	Result	Units	Qual	RL	MCL/ QCL	DF	Method	Analysis Date / By
DRINKING WATER EDB AND DBCP PARAMETERS								
1,2,3-Trichloropropane	ND	ug/L		0.05		1	E504.1	03/14/06 13:49/eli-c
1,2-Dibromo-3-chloropropane	ND	ug/L		0.02	0.2	1	E504.1	03/14/06 13:49/eli-c
1,2-Dibromoethane	ND	ug/L		0.01	0.05	1	E504.1	03/14/06 13:49/eli-c
Surr: 1,1,1,2-Tetrachloroethane	94.0	%REC			70-130		E504.1	03/14/06 13:49/eli-c
DRINKING WATER CARBAMATE PARAMETERS								
Aldicarb	ND	ug/L		0.4	3	1	E531.1	03/20/06 17:58/eli-c
Aldicarb sulfone	ND	ug/L		0.4	2	1	E531.1	03/20/06 17:58/eli-c
Aldicarb sulfoxide	ND	ug/L		0.4	4	1	E531.1	03/20/06 17:58/eli-c
Carbaryl	ND	ug/L		0.4		1	E531.1	03/20/06 17:58/eli-c
Carbofuran	ND	ug/L		0.4	40	1	E531.1	03/20/06 17:58/eli-c
3-Hydroxycarbofuran	ND	ug/L		0.4		1	E531.1	03/20/06 17:58/eli-c
Methiocarb	ND	ug/L		0.4		1	E531.1	03/20/06 17:58/eli-c
Methomyl	ND	ug/L		0.4		1	E531.1	03/20/06 17:58/eli-c
Oxamyl	ND	ug/L		0.4	200	1	E531.1	03/20/06 17:58/eli-c
Baygon	ND	ug/L		0.4		1	E531.1	03/20/06 17:58/eli-c
Surr: BDMC	97.1	%REC			70-130		E531.1	03/20/06 17:58/eli-c
DRINKING WATER SEMI-VOLATILE PARAMETERS								
Atrazine	ND	ug/L		0.1	3	1	E525.2	03/17/06 15:02/eli-b
Benzo(a)pyrene	ND	ug/L		0.1	0.2	1	E525.2	03/17/06 15:02/eli-b
bis(2-ethylhexyl)Adipate	ND	ug/L		0.5	400	1	E525.2	03/17/06 15:02/eli-b
bis(2-ethylhexyl)Phthalate	ND	ug/L		2	6	1	E525.2	03/17/06 15:02/eli-b
Butachlor	ND	ug/L		0.1		1	E525.2	03/17/06 15:02/eli-b
Metolachlor	ND	ug/L		0.1		1	E525.2	03/17/06 15:02/eli-b
Metribuzin	ND	ug/L		0.1		1	E525.2	03/17/06 15:02/eli-b
Propachlor	ND	ug/L		0.1		1	E525.2	03/17/06 15:02/eli-b
Simazine	ND	ug/L		0.1	4	1	E525.2	03/17/06 15:02/eli-b
Surr: Triphenylphosphate	96.4	%REC			70-130		E525.2	03/17/06 15:02/eli-b
Surr: 1,3-Dimethyl-2-nitrobenzene	106	%REC			70-130		E525.2	03/17/06 15:02/eli-b
Surr: Perylene-d12	92.6	%REC			70-130		E525.2	03/17/06 15:02/eli-b
Surr: Pyrene-d10	107	%REC			70-130		E525.2	03/17/06 15:02/eli-b

Report RL - Analyte reporting limit.
Definitions: QCL - Quality control limit.

MCL - Maximum contaminant level.
 ND - Not detected at the reporting limit.



LABORATORY ANALYTICAL REPORT

Client: Oglala Lakota College
Project: PWS 084690028 Piya Wiconi
Lab ID: R06030106-002
Client Sample ID: Trip Blank

Report Date: 03/27/06
Collection Date: 03/08/06
Date Received: 03/08/06
Matrix: TRIP BLANK

Analyses	Result	Units	Qual	MCL/		DF	Method	Analysis Date / By
				RL	QCL			
DRINKING WATER VOLATILE ORGANIC COMPOUNDS								
Benzene	ND	ug/L		0.50	5	1	E524.2	03/15/06 18:31/SN
Bromobenzene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Bromochloromethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Bromodichloromethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Bromoform	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Bromomethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
n-Butylbenzene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
sec-Butylbenzene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
tert-Butylbenzene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Carbon tetrachloride	ND	ug/L		0.50	5	1	E524.2	03/15/06 18:31/SN
1,2-Dichloroethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Chlorobenzene	ND	ug/L		0.50	100	1	E524.2	03/15/06 18:31/SN
Chlorodibromomethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Chloroethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Chloroform	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Chloromethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
2-Chlorotoluene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
4-Chlorotoluene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
1,2-Dibromo-3-chloropropane	ND	ug/L		1.0		1	E524.2	03/15/06 18:31/SN
Dibromomethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
1,2-Dichlorobenzene	ND	ug/L		0.50	600	1	E524.2	03/15/06 18:31/SN
1,3-Dichlorobenzene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
1,4-Dichlorobenzene	ND	ug/L		0.50	75	1	E524.2	03/15/06 18:31/SN
Dichlorodifluoromethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
1,1-Dichloroethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
1,2-Dibromoethane	ND	ug/L		0.50	5	1	E524.2	03/15/06 18:31/SN
1,1-Dichloroethene	ND	ug/L		0.50	7	1	E524.2	03/15/06 18:31/SN
cis-1,2-Dichloroethene	ND	ug/L		0.50	70	1	E524.2	03/15/06 18:31/SN
trans-1,2-Dichloroethene	ND	ug/L		0.50	100	1	E524.2	03/15/06 18:31/SN
1,2-Dichloropropane	ND	ug/L		0.50	5	1	E524.2	03/15/06 18:31/SN
1,3-Dichloropropane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
2,2-Dichloropropane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
1,1-Dichloropropene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
cis-1,3-Dichloropropene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
trans-1,3-Dichloropropene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Ethylbenzene	ND	ug/L		0.50	700	1	E524.2	03/15/06 18:31/SN
Hexachlorobutadiene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Isopropylbenzene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN

Report Definitions: RL - Analyte reporting limit.
QCL - Quality control limit.

MCL - Maximum contaminant level.
ND - Not detected at the reporting limit.



LABORATORY ANALYTICAL REPORT

Client: Oglala Lakota College
Project: PWS 084690028 Piya Wiconi
Lab ID: R06030106-002
Client Sample ID: Trip Blank

Report Date: 03/27/06
Collection Date: 03/08/06
Date Received: 03/08/06
Matrix: TRIP BLANK

Analyses	Result	Units	Qual	MCL/			Method	Analysis Date / By
				RL	QCL	DF		
DRINKING WATER VOLATILE ORGANIC COMPOUNDS								
p-Isopropyltoluene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Methylene chloride	ND	ug/L		0.50	5	1	E524.2	03/15/06 18:31/SN
Naphthalene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
n-Propylbenzene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Styrene	ND	ug/L		0.50	100	1	E524.2	03/15/06 18:31/SN
1,1,1,2-Tetrachloroethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
1,1,2,2-Tetrachloroethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Tetrachloroethene	ND	ug/L		0.50	5	1	E524.2	03/15/06 18:31/SN
Toluene	ND	ug/L		0.50	1000	1	E524.2	03/15/06 18:31/SN
1,2,3-Trichlorobenzene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
1,2,4-Trichlorobenzene	ND	ug/L		0.50	70	1	E524.2	03/15/06 18:31/SN
1,1,1-Trichloroethane	ND	ug/L		0.50	200	1	E524.2	03/15/06 18:31/SN
1,1,2-Trichloroethane	ND	ug/L		0.50	5	1	E524.2	03/15/06 18:31/SN
Trichloroethene	ND	ug/L		0.50	5	1	E524.2	03/15/06 18:31/SN
Trichlorofluoromethane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
1,2,3-Trichloropropane	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Trihalomethanes, Total	ND	ug/L		0.50	80	1	E524.2	03/15/06 18:31/SN
1,2,4-Trimethylbenzene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
1,3,5-Trimethylbenzene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Vinyl chloride	ND	ug/L		0.50	2	1	E524.2	03/15/06 18:31/SN
m+p-Xylenes	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
o-Xylene	ND	ug/L		0.50		1	E524.2	03/15/06 18:31/SN
Xylenes, Total	ND	ug/L		0.50	10000	1	E524.2	03/15/06 18:31/SN
Surr: p-Bromofluorobenzene	91.2	%REC					E524.2	03/15/06 18:31/SN
Surr: 1,2-Dichloroethane-d4	99.6	%REC					E524.2	03/15/06 18:31/SN
Surr: Toluene-d8	98.4	%REC					E524.2	03/15/06 18:31/SN

Report RL - Analyte reporting limit.
Definitions: QCL - Quality control limit.

MCL - Maximum contaminant level.
 ND - Not detected at the reporting limit.